STATE OF CONNECTICUT DEPARTMENT OF PUBLIC HEALTH

Manisha Juthani, MD Commissioner



Ned Lamont Governor Susan Bysiewicz Lt. Governor

Drinking Water Section

May 9, 2025

Mr. James Rollins Department of Public Works 189 Rowley Street Winsted, CT 06098

PUBLIC WATER SYSTEM:	Winsted Water Works Winchester, CT
CLASSIFICATION TYPE:	Community
PWSID:	CT1620011

RE: LEAD AND COPPER RULE REVISIONS INITIAL SERVICE LINE INVENTORY

Dear Mr. Rollins:

In accordance with 40 CFR § 141.84(a) of the Lead and Copper Rule Revisions (LCRR), community and non-transient non-community public water systems (water systems) are required to conduct an initial service line material inventory of each service line in their distribution system by October 16, 2024. Winsted Water Works submitted its initial service line material inventory to the Department of Public Health on October 16, 2024. This letter is to confirm that Winsted Water Works has completed the initial service line material inventory requirements and the initial customer notification requirements. See <u>40</u> CFR § 141.84(a); 40 CFR §141.85(e).

The notification to customers of known or potential service lines containing lead must be mailed annually before July 1 until the entire service connection is no longer a lead, galvanized requiring replacement, or lead status unknown service line. The water system must certify to the Department of Public Health that it delivered the annual notification and service line information to affected consumers by July 1. See <u>40</u> <u>CFR §§ 141.85(e); 40 CFR 141.90(f)(4)</u>. Please submit the completed certification and a copy of each type of notification by July 1 annually to <u>DPH.LeadandCopper@ct.gov</u>.

Lead and Copper Rule (LCR) Sampling Site Plan

Please note section <u>19-13-B102(e)(8)(A)(viii) of the Regulations of Connecticut State Agencies</u> governing lead and copper requires water systems to collect fifty percent (50%) of routine tap water lead and copper samples during each monitoring period from sites served by a lead service line (LSL). If there are insufficient number of sampling sites served by a lead service line to meet this requirement, then all the



Phone: (860) 509-7333 • Fax: (860) 509-7359 Telecommunications Relay Service 7-1-1 410 Capitol Avenue, P.O. Box 340308, MS#12DWS Hartford, Connecticut 06134-0308 <u>www.ct.gov/dph/publicdrinkingwater</u> *Affirmative Action/Equal Opportunity Employer*



sites with a lead service line must be used for compliance lead and copper sampling. The inventory indicated that there are **four (4)** lead service lines in the water system. If the lead service line sites are not in your current lead and copper sampling site pool for the LCR, Winsted Water Works is required to update their current LCR sampling site plan with **all four** sampling sites served by a lead service line. Please <u>click here</u> to review the distribution system sampling guidelines for more information on selecting lead and copper sample sites. Please submit the updated LCR sampling site plan to DPH at <u>DPH.LeadandCopper@ct.gov</u> for review by **June 8, 2025.** The sampling site plan form can be found in the Drinking Water Section website or <u>click here</u>.

If you have any questions, please contact Christine Burrill of the Lead and Copper Rule Implementation Unit at <u>christine.burrill@ct.gov</u>.

Sincerely,

Keny & coho

Kerry A. Colson Acting Branch Chief Environmental Health and Drinking Water Branch Connecticut Department of Public Health

 cc: Mr. Robert Rubbo, Director of Health, Torrington Area Health District Mr. Jeffrey Rines, Certified Operator Victor J Dubourg, Certified Operator Ms. Cindy Sek, Supervising Environmental Engineer, DPH DWS



Phone: (860) 509-7333 • Fax: (860) 509-7359 Telecommunications Relay Service 7-1-1 410 Capitol Avenue, P.O. Box 340308, MS#12DWS Hartford, Connecticut 06134-0308 <u>www.ct.gov/dph/publicdrinkingwater</u> *Affirmative Action/Equal Opportunity Employer*

